

## **MONTHLY REPORT**

**To:** David Dickson, General Manager  
**From:** James Derbin, Superintendent of Operations  
**Agenda:** January 8, 2019

**Report**  
**Date:** January 3, 2019

---

### **Monthly Highlights**

- Replaced 6" meter to Canada Cove with a Honeywell Magnetic meter. New meter will capture both high/low flows.
- Replaced 3" golf course meter
- 20 - 1.5" and 2" meters changed out
- Annual WTP meter calibrations complete
- Three new F-150s arrived and are set up with District decals, radios and emergency lights

### **Sources of Supply**

- Denniston Reservoir, Crystal Springs, Pilarcitos Lake/Wells was the sources of supply in December.

### **Projects**

- Corrpro installed the Cathodic Protection (CP) system for EG3 and serviced other tanks that have CP
- 2" South Highway 1 emergency replacement project is complete
- Denniston Contact Clarifier repairs complete, Denniston WTP started up on 12/10/18
- PG&E scheduled to set new Denniston pump station transformer on 1/22/19
- Notice to Proceed issued to Stoloski and Gonzalez for El Granada 2" project