

## **MONTHLY REPORT**

**To:** Mary Rogren, General Manager  
**From:** James Derbin, Superintendent of Operations  
**Agenda:** January 14, 2020  
**Report**  
**Date:** January 8, 2020

---

### **Monthly Highlights**

- Nunes WTP sludge scraper in sedimentation basin had an electrical short and is now rewired with new motor installed
- Installed new hydrants at 21 Sunrise Court and 280 Shelter Cove Drive
- Main break at Burning Tree Road
- P1 at Crystal Springs Pump (CSP) station had a short in the terminal box, new lugs/connectors are now installed
- Replaced center vent screen on Cahill tank
- Replaced pressure relief valves on air compressors at CSP
- Denniston Water Treatment Plant Contact Clarifier lower access hatches ordered
- Treatment staff ran Nunes Water Treatment Plant for a 10 day stretch on Pilarcitos well water only with Denniston online
- Denniston filter aid chase water pump installed by staff

### **Sources of Supply**

- **December Sources:**
  - Denniston Reservoir and Wells/Pilarcitos Wells and Crystal Springs Pump Station

### **Projects**

- New SCADA for Denniston WTP is running parallel for testing, Calcon is working on Main Street, Nunes and Crystal Springs SCADA
- Stone Dam Pipeline Project is moving along weather permitting. (~2000' of the 2600' installed to date)
- Casa Del Mar PRV Project is near completion
- EKI continues to make progress on the Grandview and Pine Willow Oak main replacement projects
- Denniston Tank Road Culvert Replacement and paving project, waiting for Geo-Hazards report from Geotech to finalize the design. Staff expects to go out to bid in February.