

STAFF REPORT

To: Coastside County Water District Board of Directors
via David Dickson, General Manager

From: James Derbin

Agenda: February 12, 2019

Report

Date: February 4, 2019

Subject: Bell Moon Pipeline Replacement Project

Recommendation:

Determine that waiving the competitive bidding requirements of Resolution 2016-09 and that contracting on a sole-source basis with Andreini Brothers Construction to replace 785 feet of 12-inch welded steel water main is in the best interest of the District project and authorize the General Manager to execute a contract with Andreini for the replacement, for a total not to exceed \$326,410.

Background:

The District's Bell Moon Pipeline is a welded steel pipe which extends about 785 feet east of Main St. along the private access road south of Lewis Foster Drive as shown in Attachment A. The existing pipeline is approximately 70 years old and is well beyond its useful life. This project will improve reliability of water service in this area.

District Engineer Jim Teter prepared the plan set, specifications, and bid documents for this work. This project will require night work due to the amount of daytime traffic and active businesses in this area. The engineer's estimate for this project was \$375,000. Andreini Brothers bid came in at \$326,410.

Because this pipeline is located within a heavily used access road running through property owned by the Andreinis and serving the Andreini businesses and Andreini tenants, staff believes it is in the best interest of the District to have Andreini perform the work. They are in the best position to coordinate construction with their own activities and those of their tenants and to avoid potential impacts. Staff believes Andreini's bid is reasonable, and it is within the engineer's estimate.

Fiscal Impact:

This project is included in the approved FY 18/19 CIP budget in the amount of \$310,000 (Bell Moon Pipeline Replacement Project, No. 07-04)

