

MONTHLY REPORT

To: David Dickson, General Manager
From: James Derbin, Superintendent of Operations
Agenda: February 12, 2019

Report

Date: February 5, 2019

Monthly Highlights

- Drained, cleaned and inspected Cahill tank
- Replaced 2 hydrants:
 - Burning Tree/Greenbrier
 - Main/Metzgar
- Replaced seven 1.5" and 2" meters, two more 2" to go
- Fence repairs at tank sites
- Alves tank altitude valve delay pilot adjusted so the tank will drop 3 feet before refilling
- Rebuilt Alves Pump Station chlorine dosing system
- Annual Nunes WTP tour for Seacrest School first graders, parents and teachers
- San Francisco State University, Industrial Assessment Center, School of Engineering staff and students toured Crystal Springs, Nunes WTP, Denniston WTP and Pump Station with District staff to conduct a free Department of Energy funded Energy Audit.

Sources of Supply

- January Sources:
 - Denniston Reservoir and Wells, Crystal Springs, Pilarcitos Lake/Wells

Projects

- El Granada 2" replacement project is complete
- PG&E contractor set new Denniston pump station transformer on 1/22/19
- Pilarcitos PRV valve replacement project complete