

## **MONTHLY REPORT**

**To:** David Dickson, General Manager  
**From:** James Derbin, Superintendent of Operations  
**Agenda:** December 11, 2018

**Report**  
**Date:** December 5, 2018

---

### **Monthly Highlights**

- Replaced 5 fire hydrants:
  - 419 Kehoe Avenue
  - 574 Kelly Street
  - 110 Cortez, Miramar
  - 16 Mirada Road, Miramar
  - Mirada Road/Medio, Miramar
- Replaced 4" meter to Ritz with a Honeywell magnetic meter and the three valves in vault. New meter will capture both high/low flows.
- Replaced 6" Air/Vacuum Relief Valve on main to Cahill tank
- 40 AMR replacements
- 20 meter change outs that PMI could not complete due to field conditions
- Installed new delay pilot on Alves tank Cla-Val altitude valve

### **Source of Supply**

- Crystal Springs/Pilarcitos Wells was the sources of supply in November

### **Projects**

- 2" South Highway 1 emergency replacement project is 90% complete. Contractor is finishing up installing Air/Vacuum Relief Valves and planning for abandonment of old 2" connection in Hwy 1. Service pressure to these customers has greatly improved.
- Princeton Welding completed welding repairs to the Denniston Contact Clarifiers and screens, ERS installed new media in both. Plan to start Denniston WTP on Friday 12/7/18.
- Denniston pump station transformer upgrade nearing completion. Awaiting PGE final and setting new transformer. Old transformer is back on for now.
- Slide gate for Denniston Reservoir large spillway installed
- El Granada 2" project, lowest bid was Stoloski and Gonzalez Inc.