

Coastside County Water District

Checklist To Be Completed By Applicant

I certify that the subject project meets the specified requirements of the Coastside County Water District Indoor Water Use Efficiency Ordinance.

Applicant Name (print)

Applicant Signature

Date

Project Information

Single Family Multi-Family Commercial Institutional Irrigation only Industrial Mixed Use Other

Applicant Name:

Contact Name and Phone:

Contact Email:

Applicant Mailing Address:

Project Site Address:

Project Assessor Parcel Number:

Parcel Area (sq.ft.):

Landscaped Area (sq.ft.)

Number of Units:

Fixture Type	Requirements			Number of Fixtures	
	Residential	Non-Residential	Unit of measurement	Residential	Non-Residential
Toilets	≤ 1.28	≤ 1.28	gallons per flush		
	≥ 350	≥ 350	grams per flush		
Showerheads	≤ 2.0	≤ 2.0	gallons per minute		
Bathroom faucets	≤ 1.5	≤ 0.5	gallons per minute		
Kitchen faucets	≤ 1.8	≤ 1.8	gallons per minute		
Utility faucets	≤ 1.8	≤ 1.8	gallons per minute		
Dishwashers	ENERGY STAR	ENERGY STAR	--		
Metering faucets	--	≤ 0.25	gallons per cycle		
Urinals	≤ 0.5	≤ 0.5	gallons per flush		
Cooling towers	≥ 5	≥ 5	cycles of concentration		
	or ≥ 2.5	or ≥ 2.5	Langlier Saturation Index		
Food steamers	--	Boilerless or Self-Contained	--		
Ice machines	--	≤ 25 Air-cooled	gallons/100 lbs ice		
Pre-rinse spray valves		≤ 1.28	gallons per minute		
Automatic vehicle wash facilities	--	≥ 50% of the water is recycled on site	--		
Commercial refrigeration	--	Closed loop or Air-cooled	--		