

## MONTHLY REPORT

**To:** Mary Rogren, General Manager

**From:** Sean Donovan, Water Treatment Operations Manager  
Darin Sturdivan, Water Distribution Operations Manager  
Todd Schmidt, Water Treatment Supervisor  
Dustin Jahns, Distribution Supervisor

**Agenda:** February 10, 2026

**Report**  
**Date:** February 6, 2026

---

### Monthly Highlights

- Replaced air scour actuators on Nunes WTP filter #4. (Warranty work.)
- Repaired/upgraded doors at both WTP's to improve security of the premises.
- Replaced three actuator motors at Denniston WTP.
- Continued prep/painting of outdoor piping at Denniston WTP.
- Added remote/mobile data entry capability to the District's current Operations data collection and reporting database.
- Replaced Ford F -150 that was damaged beyond repair in December 2025 storm.
- Replaced radio at Miramontes Tank.
- GSW drilled new well 5 in Pilarcitos Canyon, installed casing and started installation of well screen.
- El Granada Tank 3 site: all repairs completed (resulting from damage in the December 2025 storm) and generator is back online.
- Pilarcitos Canyon - continued tree work to clear downed trees from December 2025 storm.
- SCADA improvements completed at Crystal Springs Pump Station.

**Sources:** Pilarcitos Reservoir, Denniston Creek, Pilarcitos Wells.

### Main leaks/service leaks:

- 2008 Bordeaux Ln.

### Hydrants replaced:

- 150 Bridgeport

### Projects

- EKI Environment and Water, Inc.
  - Provided peer review of DN Tank project coordination/engineering.
  - Submittal review and tracking of Pilarcitos Canyon Well Project.
  - Provided construction support for Pilarcitos Canyon Wells Project.

**STAFF REPORT**

**Agenda: February 10, 2026**

**Subject: Operations Report**

Page 2

- Continued work on environmental permitting requirements for Pilarcitos Culvert Repair and Pilarcitos Slide Repair Project.
- HDR, Inc.
  - HDR continued work on DN Tank submittals and plan modifications and coordination of subcontractors.