

MONTH		June-24									
Coastside County Water District Monthly Discharge Report											
EMERGENCY MAIN AND SERVICE REPAIRS											
C o u n t	Date Reported Discovered	Time Reported	Date Repaired	Time Repaired	Estimated Duration of Leak	(Identifier) Location	Estimated Water Volume Loss (MG)	Class Type	Material Type	Size (Inches)	Work Order Number
1	6/18/2024	1030	6/20/2024	1530	53 Hours	460 Poplar Street	0.005	Service	Copper	3/4"	8116
2											
3											
4											
5											
6											
7											
8											
Total							0.005				

OTHER DISCHARGES	
Total Volumes (MG)	
Flushing Program	0.625
Reservoir Cleaning	0.000
Automatic Blowoffs	0.154
Dewatering Operations	0.000
Other (includes flow testing)	0.000
DISCHARGES GRAND TOTAL (MG)	
0.779	