


## Information Sheet



# Public Works Main (pipeline) Line Extension | Fire Hydrants

Coastside County Water District

Coastside County Water District's (District) jurisdiction covers the City of Half Moon Bay and the unincorporated areas of Moonridge, Miramar, El Granada, and Princeton. The District's jurisdiction also includes unincorporated areas along Highway 92 (San Mateo Road) terminating at Pilarcitos Creek Road. The planning authorities within the District's jurisdiction are the County of San Mateo and the City of Half Moon Bay.

### Pipeline Extensions, Subdivisions and Upgrades of the Water Distribution System

If your project requires an extension or upgrade to the existing water distribution system infrastructure, you are required to apply for a main-line extension. This is a separate application and approval. It takes a minimum of six months to review a pipeline extension project. You will be provided with the District's requirements during review by the District Engineer. A water service agreement is required.

In order to size the District's infrastructure, approvals (building and fire permits) for developing the lot(s) that require the pipeline extension are required. The submittals are in parallel.

### Required Submittals for New Construction

- ü A complete printed set of the most current building plans, as required and approved by the planning authority.
  - Civil Drawings •Irrigation Drawings •Landscape Drawings
- ü Other submittals, as required

Coastside County Water District  
766 Main Street | Half Moon Bay CA 94019  
[www.coastsidewater.org](http://www.coastsidewater.org) | (650) 726-4405

## Approved Contractors

Any work that involves the District's distribution system infrastructure requires a properly licensed contractor with a valid "A" or "C34" license. A list of contractors is available from the District upon request. An inspection by District staff is required prior to backfilling the water service connection, pipeline extension, pipeline upgrade or fire hydrant installation.

## Charges and Fees

The District charges the applicant for the plan review.

### **When Planning Your Project, consider the items below:**

- Ø *Water services shall not be in the same trench as other utilities.*
- Ø *If fire service is required, each parcel (APN) must have its own fire service connection.*
- Ø *Each parcel (APN) must have its own water capacity and water service connection.*
- Ø *The fire service connection is separate from the domestic water service connection.*
- Ø *Be sure to show the location of the fire service connection, domestic water service connection and irrigation water service connection on the civil and landscape drawings.*
- Ø *All water services (meters) and fire hydrants must be in a public utility easement and accessible at all times to District staff. Do not place meters in driveways or parking areas.*
- Ø *Public utility easements must be shown (approved) by the District*